



Test Report

Report No.: ASH15-030494-02

Date: Aug 27 2015

Client name: [REDACTED]
Client address: [REDACTED]
Sample name: Ultrafiltration Filter for extra low pressure
Sample Batch No.: PS001
Product Date: 2015-7-31
Manufacturer: [REDACTED]

Above information and sample(s) was/were submitted and certified by the client, SGS quoted the information with no responsibility as to the accuracy, adequacy and/or completeness.

SGS Sample No.: ASH15-030494.001
SGS reference No.: SHAFD1516554000
Date of sample received: Aug 18 2015
Testing period: Aug 18 2015 ~ Aug 27 2015

TEST(S) REQUESTED:

Selected test(s) as requested by applicant: immerse sample into 2950mL exposure water and maintained in dark place for 24h ± 1h at a temperature of 25°C ± 5°C. Then the extractant water is collected and analyzed.

TEST METHOD(S):

Please refer to the next page(s)

TEST RESULT(S):

Please refer to the next page(s)

This test report is in Chinese and maybe translated into other languages, the Chinese version shall prevail.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested. This document cannot be used for publicity, without prior written approval of the SGS.



SGS-CSTC Standards Technical Services (Shanghai) Co.,Ltd.

Page 1 of 5



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

SGS (Shanghai) Technical Services Co., Ltd.
Testing Center (China) (Shanghai)

3rd Building, No. 889, Yishan Road, Shanghai, China 200233 t (86-21) 6140 2501 f (86-21) 6140 2547 www.sgs.com.cn
中国 - 上海 - 宜山路889号3号楼 邮编: 200233 t (86-21) 6140 2501 f (86-21) 6140 2547 e sgs.china@sgs.com

Member of the SGS Group (SGS SA)

Test Report

Report No: ASH15-030494-02

Date: Aug 27 2015

TEST METHOD(S):

Hygienic safety extraction testing: Refer to MOH Standard for Hygienic Safety Evaluation of Equipment and Protective Materials in Drinking Water Appendix A Test Method of Equipment in Drinking Water.

Color, Turbidity, Odor and taste, Visible substance, pH, Volatile phenolic compounds, Total dissolved solids: GB/T 5750.4-2006 Standard examination methods for drinking water – Organoleptic and physical parameters

Oxygen consumption (count with O₂): GB/T 5750.7-2006 Standard examination methods for drinking water – Aggregate organic parameters

Arsenic (As), Cadmium (Cd), Aluminum (Al), Lead (Pb), Mercury (Hg), Iron (Fe), Manganese (Mn), Copper (Cu), Zinc (Zn), Silver (Ag): GB/T 5750.6 - 2006 Standard examination methods for drinking water – Metal Parameters Inductively coupled plasma mass spectrometry

Chromium-VI: GB/T 5750.6-2006 Standard examination methods for drinking water – Metal Parameters

Chloroform, Carbon tetrachloride: GB/T 5750.8-2006 Standard examination methods for drinking water – Organic parameters

Fluoride, Nitrate: GB/T 5750.5-2006 Standard examination methods for drinking water–Nonmetal parameters

TEST RESULT(S):

Test items	Unit(s)	Test methods	Test results			Increased amount		Requirements (Standard for Hygienic Safety Evaluation of Equipment and Protective Materials in Drinking Water)	Single determination
			Extractant water		Control exposure water	Unit 1	Unit 2		
			Unit 1	Unit 2					
Color	Pt-Co color units	GB/T 5750.4-2006	<5	<5	<5	<5	<5	Increased amount ≤5	Conform
Turbidity	NTU	GB/T 5750.4-2006	<0.2	<0.2	<0.2	<0.2	<0.2	Increased amount ≤0.2	Conform
Odor and taste	/	GB/T 5750.4-2006	None	None	None	/	/	No abnormal odor and taste	Conform
Visible substance,	/	GB/T 5750.4-2006	None	None	None	None	None	Absence	Conform
pH	/	GB/T 5750.4-	8.26	8.41	8.44	0.18	0.03	Variation≤	Conform

SGS-CSTC Standards Technical Services (Shanghai) Co.,Ltd.

Page 2 of 5



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/terms-and-conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/terms-and-conditions/terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

Attention: To check the authenticity of testing/inpection report & certificate, please contact us at telephone: (86-755)8307 1443, or email: CN_Doocheck@sgs.com

3rd Building, No.889, Yishan Road, Shanghai, China 200233 | (86-21)61402501 | (86-21)61402547 | www.sgs.com.cn
 中国·上海·宜山路889号3号楼 邮编:200233 | (86-21)61402501 | (86-21)61402547 | e.sgs.china@sgs.com

Member of the SGS Group (SGS SA)

Test Report

Report No: ASH15-030494-02

Date: Aug 27 2015

Test items	Unit(s)	Test methods	Test results			Increased amount		Requirements (Standard for Hygienic Safety Evaluation of Equipment and Protective Materials in Drinking Water)	Single determination
			Extractant water		Control exposure water	Unit 1	Unit 2		
			Unit 1	Unit 2					
		2006						0.5	
Total dissolved solids	mg/L	GB/T 5750.4-2006	251	251	264	-13	-13	Increased amount ≤ 10	Conform
Oxygen consumption (as O ₂)	mg/L	GB/T 5750.7-2006	0.66	0.66	0.66	0	0	Increased amount ≤ 1	Conform
Arsenic (As)	mg/L	GB/T 5750.6-2006	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	Increased amount ≤ 0.001	Conform
Cadmium (Cd)	mg/L	GB/T 5750.6-2006	<0.0002	<0.0002	<0.0002	<0.0002	<0.0002	Increased amount ≤ 0.0005	Conform
Chromium-VI	mg/L	GB/T 5750.6-2006	<0.004	<0.004	<0.004	<0.004	<0.004	Increased amount ≤ 0.005	Conform
Aluminum (Al)	mg/L	GB/T 5750.6-2006	<0.010	<0.010	<0.010	<0.010	<0.010	Increased amount ≤ 0.02	Conform
Lead (Pb)	mg/L	GB/T 5750.6-2006	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	Increased amount ≤ 0.001	Conform
Mercury (Hg)	mg/L	GB/T 5750.6-2006	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	Increased amount ≤ 0.0002	Conform
Iron (Fe)	mg/L	GB/T 5750.6-2006	<0.007	<0.007	<0.007	<0.007	<0.007	Increased amount ≤ 0.06	Conform
Manganese (Mn)	mg/L	GB/T 5750.6-2006	<0.005	<0.005	<0.005	<0.005	<0.005	Increased amount	Conform

SGS-CSTC Standards Technical Services (Shanghai) Co.,Ltd.
Page 3 of 5



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/terms-and-conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/terms-and-conditions/terms-e-document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-795)83071443, or email: CN.Doccheck@sgs.com

SGS (Shanghai) Technical Services (Shanghai) Co., Ltd.
Testing Center (China) (Shanghai)

3rd Building, No. 889, Yishan Road, Shanghai, China 200233 t (86-21)61402501 f (86-21)61402547 www.sgs.com.cn
中国·上海·宜山路889号3号楼 邮编:200233 t (86-21)61402501 f (86-21)61402547 e sgs.china@sgs.com

Member of the SGS Group (SGS SA)

Test Report

Report No: ASH15-030494-02

Date: Aug 27 2015

Test items	Unit(s)	Test methods	Test results			Increased amount		Requirements (Standard for Hygienic Safety Evaluation of Equipment and Protective Materials in Drinking Water)	Single determination
			Extractant water		Control exposure water	Unit 1	Unit 2		
			Unit 1	Unit 2					
								≤0.02	
Copper (Cu)	mg/L	GB/T 5750.6-2006	<0.006	<0.006	<0.006	<0.006	<0.006	Increased amount ≤0.2	Conform
Zinc (Zn)	mg/L	GB/T 5750.6-2006	<0.002	<0.002	<0.002	<0.002	<0.002	Increased amount ≤0.2	Conform
Silver (Ag)	mg/L	GB/T 5750.6-2006	<0.001	<0.001	<0.001	<0.001	<0.001	Increased amount ≤0.005	Conform
Fluoride	mg/L	GB/T 5750.5-2006	0.009	0.009	0.008	0.001	0.001	Increased amount ≤0.1	Conform
Nitrate(as N)	mg/L	GB/T 5750.5-2006	0.008	0.010	0.011	-0.003	-0.001	Increased amount ≤1	Conform
Chloroform	mg/L	GB/T 5750.8-2006	0.0036	0.0038	0.0031	0.0005	0.0007	Increased amount ≤0.006	Conform
Carbon tetrachloride	mg/L	GB/T 5750.8-2006	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	Increased amount ≤0.0002	Conform
Volatile Phenolic Compounds (as phenol)	mg/L	GB/T 5750.4-2006	<0.002	<0.002	<0.002	<0.002	<0.002	Increased amount ≤0.002	Conform

Remark: 1. the test result of control exposure water is obtained from SGS lab.

SGS-CSTC Standards Technical Services (Shanghai) Co.,Ltd.
Page 4 of 5



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755)61071443, or email: CN.Doccheck@sgs.com

SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd.
Testing Center (China Service Locality)

3rd Building, No. 889, Yishan Road, Shanghai, China 200233 | t (86-21)61402501 | f (86-21)61402547 | www.sgs.com.cn
中国·上海·宜山路889号3号楼 邮编:200233 | t (86-21)61402501 | f (86-21)61402547 | e sgs.china@sgs.com

Test Report

Report No: ASH15-030494-02

Date: Aug 27 2015

SAMPLE DESCRIPTION: Ultrafiltration Filter for extra low pressure



*** End ***

SGS-CSTC Standards Technical Services (Shanghai) Co.,Ltd.
Page 5 of 5

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions_sgs and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents_sgs. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

Attention: To check the authenticity of testing inspection report & certificate, please contact us at telephone: (86-755)8167 1443, or email: CN.Doccheck@sgs.com



SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd.
Testing Center

3rd Building, No. 889, Yishan Road, Shanghai, China 200233
中国·上海·宜山路889号3号楼

Tel: (86-21) 6140 2501 | Fax: (86-21) 6140 2547
Tel: (86-21) 6140 2501 | Fax: (86-21) 6140 2547

www.sgs.com
sgs.china@sgs.com

Member of the SGS Group (SGS SA)




PONY

Pony Testing International Group

Test Results


Report ID : MDB7IUGU15973705

page 2 of 2

Sample Description and Number	Test Items	Test Results	
U15973705 Water straw 	Total coliform group	Bacteria liquid concentration, CFU/mL	2.4×10^3
		Purification of liquid bacteria content, CFU/mL	3.0×10^2
		Aseptic rate, %	97.5
	Colonies total	Bacteria liquid concentration, CFU/mL	2.1×10^5
		Purification of liquid bacteria content, CFU/mL	6.9×10^3
		Aseptic rate, %	96.7

Aseptic rate testing steps: (1) Before the experiment, soaking the filter and water pipe connector with 2000 times diluted H_2O_2 for 20 min; (2) Match the well activated bacteria to bacteria liquid, the colonies total is 10^5 CFU/mL, total coliform ground is 10^3 CFU/mL; (3) Connecting the filter and water pipe, filtrate the bacteria liquid, after water samples filtered out 100 mL start to collect, the obtained is the Purification of liquid; (4) The plate count method measuring the Purification of liquid bacteria content.

End of Report



www.ponytest.com

Hotline 400-819-5688

PONY 谱尼测试

Pony Testing International Group

谱尼测试集团有限公司
 深圳市南山区创业路中兴工业城六楼一层

Beijing Lab: (010) 82618116 Changchun Lab: (0431) 85150008 Shanghai Lab: (021) 64851994 Shenzhen Lab: (0755) 26050909
 Qingdao Lab: (0532) 88766866 Harbin Lab: (0451) 88184651 Ningbo Lab: (0574) 87736499 Guangzhou Lab: (020) 89234310
 Tianjin Lab: (022) 27360730 Dalian Lab: (0411) 84650820 Hangzhou Lab: (0571) 87219096 Wuhan Lab: (027) 83997127
 Xuzhou Lab: (0991) 6684186 Zhengzhou Lab: (0371) 69350670 Suzhou Lab: (0512) 62997900 Xiamen Lab: (0592) 5568048